



PARTIAL FLOOR - LIGHTING PLAN
Scale: 1/8" = 1'-0"



MEP Consultant
Rene A. Culross
Rene A. Culross, P.E., PLLC
1820 Hunting Green Drive
Fort Worth, TX 76134
817-798-6642
raculross@gmail.com
F-12230

GENERAL NOTES

- RE: E0.1 FOR ELECTRICAL SYMBOLS, ADDITIONAL GENERAL NOTES, AND ABBREVIATIONS.
- RE: E0.2 FOR ELECTRICAL SPECIFICATIONS.
- RE: E0.3 FOR LIGHTING CONTROL DETAILS.
- RE: E5.1 FOR BRANCH WIRING SCHEDULE FOR WIRE SIZES.
- RE: E6.1 OR PANELBOARD SCHEDULES.
- RE: E6.2 FOR LIGHT FIXTURE SCHEDULE.
- RE: E6.2 FOR MECHANICAL / ELECTRICAL SCHEDULE.
- LIGHTING CONTROLS TO INCLUDE "DAYLIGHTING ZONE" REQUIREMENTS.
- PROVIDE ADDITIONAL CONDUCTOR WITHIN CIRCUITS WHERE REQUIRED FOR FOR UNSWITCHED POWER TO EXIT SIGNS AND EMERGENCY BALLAST / DRIVER SYSTEMS.
- DESIGNATION REPRESENTS:
(E) EXISTING ELECTRICAL DEVICE TO REMAIN AS IS.
(R) EXISTING ELECTRICAL DEVICE TO BE REMOVED IN ITS ENTIRETY.
(RR) REMOVE AND RELOCATED EXISTING ELECTRICAL DEVICE.
(NL) NEW LOCATION FOR EXISTING RELOCATED ELECTRICAL DEVICE.
(CCT) EXISTING LIGHTING BRANCH CIRCUITING TO BE RE-USED FOR NEW LIGHT FIXTURES.

NOTES BY SYMBOL "#"

- EXISTING PANEL IS NOT LABELED. FOR DRAWING PURPOSES THIS EXISTING PANEL WILL BE IDENTIFIED AS "A".
- EXISTING PANEL IS NOT LABELED. FOR DRAWING PURPOSES THIS EXISTING PANEL WILL BE IDENTIFIED AS "B".
- NO ELECTRICAL WORK REQUIRED IN THIS ROOM. MAINTAIN LIGHTING AND POWER BRANCHING CIRCUITING CONTINUITY. EXISTING SWITCH TO REMAIN AS IS AND MAINTAIN SWITCHING CONFIGURATION. UNLESS NOTED OTHERWISE.
- RE-USE EXISTING LIGHTING BRANCH CIRCUITING TO RE-CONNECT TO NEW LIGHT FIXTURE(S) INDICATED.
- EXTERIOR LIGHTING CONTACTOR AND BY-PASS SWITCH. RE: 1/E0.3 EXTERIOR LIGHTING CONTACTOR WIRING DIAGRAM FOR ADDITIONAL INFORMATION.
- EXISTING LIGHT SWITCHES (TOTAL OF 27) ARE TO REMAIN AS IS. MAINTAIN CIRCUITING CONTINUITY AND SWITCHING CONFIGURATION.
- NEW TRACK LIGHTING. PROVIDE A NEW LIGHTING CIRCUIT AS INDICATED. ROUTE CONDUIT BACK TO EXISTING PANELBOARD "M1-SECT-1" AND EXISTING BANK OF SWITCHES. PROVIDE DIMMER 400 WATT DIMMERS. PAINT EXPOSED CONDUIT TO MATCH WOOD CEILING. COORDINATE COLOR WITH THE ARCHITECTS PRIOR TO PAINTING.

APPROVED

Reviewed for Code Compliance
ProjectName: C2-24-02038 &
CR-24-00667
Date: 4/25/2024
Approved plans in no way
excludes items that may be found
in the field and shall not be
construed to be a permit or
approval of any violation of any
code provision.

ARCHITECTURE

SCOTT MARTSOLF - ARCHITECT

815 Daggett Avenue
Fort Worth, Texas 76104
Phone: (817) 820-0005

ST. JUDE CATHOLIC CHURCH

PARISH HALL REMODEL & CONNECTOR

500 E DALLAS ST.
MANSFIELD, TX 76063

12/29/23 ADDENDUM #1

PERMIT SET

Drawing Title:

PARTIAL FLOOR -
LIGHTING PLAN

Project No.

2307

Date:

1/12/2024

Sheet No.

E2.1