

ARCHITECTURE
SCOTT MARTSOLF - ARCHITECT

815 Daggett Avenue
Fort Worth, Texas 76104
Phone: (817) 820-0005

**ST. JUDE
CATHOLIC
CHURCH**

**PARISH HALL
REMODEL &
CONNECTOR**

500 E DALLAS ST.
MANSFIELD, TX 76063

12/29/23 ADDENDUM #1

PERMIT SET

Drawing Title:

PARTIAL CRAWL SPACE -
POWER & DATA PLAN

Project No.
2307

Date:
1/12/2024

Sheet No.


E3.3

GENERAL NOTES

- RE: E0.1 FOR ELECTRICAL SYMBOLS, ADDITIONAL GENERAL NOTES, AND ABBREVIATIONS.
- RE: E0.2 FOR ELECTRICAL SPECIFICATIONS.
- RE: E0.3 FOR LIGHTING CONTROL DETAILS.
- RE: E5.1 FOR BRANCH WIRING SCHEDULE FOR WIRE SIZES.
- RE: E6.1 OR PANELBOARD SCHEDULES.
- RE: E6.2 FOR LIGHT FIXTURE SCHEDULE.
- RE: E6.2 FOR MECHANICAL / ELECTRICAL SCHEDULE.
- LIGHTING CONTROLS TO INCLUDE "DAYLIGHTING ZONE" REQUIREMENTS.
- PROVIDE ADDITIONAL CONDUCTOR WITHIN CIRCUITS WHERE REQUIRED FOR UNSWITCHED POWER TO EXIT SIGNS AND EMERGENCY BALLAST / DRIVER SYSTEMS.
- DESIGNATION REPRESENTS:
(X) EXISTING ELECTRICAL DEVICE TO REMAIN AS IS.
(R) EXISTING ELECTRICAL DEVICE TO BE REMOVED IN ITS ENTIRETY.
(RR) REMOVE AND RELOCATED EXISTING ELECTRICAL DEVICE.
(NL) NEW LOCATION FOR EXISTING RELOCATED ELECTRICAL DEVICE.
CCT EXISTING LIGHTING BRANCH CIRCUITING TO BE RE-USED FOR NEW LIGHT FIXTURES.


NOTES BY SYMBOL "Ⓢ"

- MOUNT LIGHT SWITCH ADJACENT TO THE CRAWL SPACE ACCESS DOOR. PROVIDE ANOTHER LIGHT FIXTURE ADJACENT TO THE EXHAUST FAN. FIXTURES TO BE MOUNTED TIGHT TO THE STRUCTURE IF POSSIBLE OR CHAIN HUNG 2" INCHED FROM STRUCTURE.
- MOUNT RECEPTACLE ADJACENT TO THE EXHAUST FAN. PROVIDE A WEATHERPROOF IN-USE COVER.



PARTIAL CRAWL SPACE - POWER PLAN

Scale: 1/8" = 1'-0"



MEP Consultant
Rene A. Culross
Rene A. Culross, P.E., PLLC
1820 Hunting Green Drive
Fort Worth, TX 76134
817-798-6642
raculross@gmail.com
F-12230