

MECHANICAL SYMBOLS AND ABBREVIATIONS

NOTE: NOT ALL SYMBOLS AND ABBREVIATIONS SHOWN ARE NECESSARILY USED ON THE DRAWINGS

GENERAL NOTES

- PERFORM ALL WORK IN ACCORDANCE WITH ALL APPLICABLE CODES AND AUTHORITIES HAVING JURISDICTION. PROVIDE ALL PERMITS, INSPECTIONS, LICENSES AND FEES. FURNISH ALL LABOR, EQUIPMENT, SUPPLIES AND MATERIALS NECESSARY TO PROVIDE COMPLETE AND OPERATIONAL SYSTEMS.
2. THE DRAWINGS AND SPECIFICATIONS INDICATE THE GENERAL DESIGN AND ARRANGEMENT OF PIPES, FIXTURES, EQUIPMENT, SYSTEMS, ETC. INFORMATION SHOWN IS DIAGRAMMATIC IN CHARACTER AND DOES NOT NECESSARILY INDICATE EVERY REQUIRED OFFSET, FITTING, ETC. DO NOT SCALE THE DRAWINGS FOR DIMENSIONS. TAKE ALL DIMENSIONS, MEASUREMENTS, EQUIPMENT LOCATIONS, LEVELS, ETC. FROM THE ARCHITECTURAL DRAWINGS AND FROM THE EQUIPMENT TO BE FURNISHED. PIPING MAY BE RELOCATED OR OFFSET FOR PROPER CLEARANCES OR TO AVOID CONFLICTS WITH OTHER TRADES. THE DESIGN INTENT (I.E. PITCHES, VELOCITIES, PRESSURE DROPS, VOLTAGE DROPS, ETC) CANNOT BE GREATLY ALTERED WITHOUT THE APPROVAL OF THE ARCHITECT. THE COST OF THESE DEVIATIONS TO AVOID INTERFERENCE SHALL BE PART OF THE ORIGINAL CONTRACT BID.
3. CONFER AND COOPERATE WITH ALL OTHER TRADES TO COORDINATE THEIR WORK. COORDINATION SHALL INCLUDE, BUT SHALL NOT BE LIMITED TO MATERIALS AND EQUIPMENT ROUTED IN CEILING AND WALL CAVITIES, EQUIPMENT ARRANGEMENT IN MECHANICAL SPACES, INCLUDING EQUIPMENT CLEARANCE REQUIREMENTS, ELEVATIONS AND DIMENSIONS OF STRUCTURAL MEMBERS AND OPENINGS, ETC. NOTIFY THE ARCHITECT OF ANY CONFLICTS.
4. BASE FINAL INSTALLATION OF MATERIALS AND EQUIPMENT ON ACTUAL DIMENSIONS AND CONDITIONS AT THE PROJECT SITE. FIELD MEASURE FOR MATERIALS AND EQUIPMENT REQUIRING EXACT FIT. NO EXTRAS WILL BE GIVEN FOR THE CONTRACTOR'S FAILURE TO FIELD COORDINATE.
5. THE OWNER OR ENGINEER ARE NOT RESPONSIBLE FOR THE CONTRACTOR'S SAFETY PRECAUTIONS OR FOR MEANS, METHODS, TECHNIQUES, CONSTRUCTION SEQUENCES, OR PROCEDURES REQUIRED TO PERFORM THE WORK.
6. LOCATE ALL EQUIPMENT THAT MUST BE SERVICED, OPERATED, OR MAINTAINED IN FULLY ACCESSIBLE POSITIONS. EQUIPMENT SHALL INCLUDE (BUT NOT LIMITED TO) VALVES, MOTORS, CONTROLLERS, SWITCHGEAR, AND DRAIN POINTS IF REQUIRED FOR BETTER ACCESSIBILITY. FURNISH ACCESS DOORS FOR THIS PURPOSE. MINOR DEVIATIONS FROM THE DRAWINGS MAY BE ALLOWED TO PROVIDE FOR BETTER ACCESSIBILITY. ANY CHANGES SHALL BE APPROVED BY THE ARCHITECT AND CONSTRUCTION MANAGER/GENERAL CONTRACTOR PRIOR TO MAKING THE CHANGE.
7. PROVIDE ACCESS DOORS, WALL OPENINGS, ROOF OPENINGS OR ANY OTHER CONSTRUCTION REQUIREMENT NEEDED TO ACCOMMODATE THE MECHANICAL EQUIPMENT. LOCATIONS OF THESE OPENINGS SHALL BE SUBMITTED IN SUFFICIENT TIME TO BE INSTALLED IN THE NORMAL COURSE OF WORK.
8. COORDINATE ELECTRICAL REQUIREMENTS OF APPROVED MECHANICAL EQUIPMENT WITH THE ELECTRICAL SUB-CONTRACTOR PRIOR TO THE PURCHASE AND INSTALLATION OF ANY ELECTRICAL EQUIPMENT, DEVICES, WIRING, OR CONDUIT.
9. PROVIDE GENERAL CONTROL WIRING, THERMOSTATS, MOTORIZED DAMPERS AND CONDUIT ASSOCIATED WITH HVAC EQUIPMENT. COORDINATE THE LOCATION OF ALL THERMOSTATS, ROOM SENSORS, ETC WITH THE ARCHITECT AND ALL OTHER TRADES PRIOR TO INSTALLATION. IF A CONFLICT WITH MILLWORK, LIGHT SWITCHES, WINDOWS, ETC. EXISTS, NOTIFY THE ARCHITECT OF THE POTENTIAL INTERFERENCE PRIOR TO INSTALLATION. INSTALL THERMOSTATS WITH PROTECTIVE LOCKING COVER, CENTERED AT 4'-0" ABOVE FINISHED FLOOR, UNLESS OTHERWISE INDICATED. COMPLY WITH THE PROVISIONS OF THE AMERICANS WITH DISABILITIES ACT (ADA) AND THE TEXAS ACCESSIBILITY'S STANDARD (TAS).
10. ALL DIMENSIONS SHOWN ON THE DRAWINGS FOR DUCTWORK ARE NET INSIDE CLEAR DIMENSIONS. FOR RECTANGULAR DUCT, THE FIRST FIGURE OF THE DUCT SIZE INDICATES THE DIMENSION OF THE FACE SHOWN. VERIFY THAT THE DUCTWORK SPECIFIED WILL FIT IN THE SPACE AVAILABLE USING THE ARCHITECTURAL, STRUCTURAL AND ELECTRICAL DRAWINGS AS REFERENCE PRIOR TO FABRICATION AND INSTALLATION. ROUND DUCT OF EQUAL NET INSIDE CLEAR AREA MAY BE USED IN LIEU OF RECTANGULAR DUCT.
11. PROVIDE TURNING VANES ON ALL RECTANGULAR SUPPLY, EXHAUST AND RETURN DUCTWORK INCLUDING THE TOP AND BOTTOM OF VERTICAL DUCTS.
12. PROVIDE A LOCKING QUADRANT VOLUME DAMPER AT THE TAP OF EACH RUN-OUT TO SUPPLY AND EXHAUST AIR DEVICES FOR BALANCING PURPOSES. THE RUN-OUT DUCT SIZE IS THE SAME SIZE AS THE DIFFUSER OR GRILLE NECK SIZE UNLESS OTHERWISE NOTED ON PLAN.
13. WHERE DAMPERS ARE LOCATED ABOVE HARD CEILINGS PROVIDE CONCEALED ZONE REGULATORS. REGULATORS SHALL NOT BE LOCATED IN CORRIDORS, PATIENT CARE, OR TREATMENT AREAS. EACH REGULATOR SHALL BE LABELED PER THE SPECIFICATIONS.
14. REFER TO ARCHITECTURAL DRAWINGS FOR LOCATION OF ALL FIRE RATED WALLS AND CEILINGS. PROVIDE FIRE DAMPERS AND/OR COMBINATION FIRE/SMOKE DAMPERS IN DUCTWORK AT ALL LOCATIONS WHERE DUCTS PASS THROUGH FIRE RATED ASSEMBLY. MECHANICAL SUB-CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING AND INSTALLING FIRE AND FIRE/SMOKE DAMPERS. COORDINATE CONSTRUCTION REQUIREMENTS AND PROVISIONS FOR CONNECTIONS TO FIRE ALARM SYSTEM.
15. EXTERIOR DUCTWORK: SUPPLY AND RETURN DUCTWORK LOCATED OUTSIDE, EXPOSED TO AMBIENT CONDITIONS SHALL BE INTERNALLY LINED WITH 2" DUCT LINER. BREAK SHEET METAL IN A MANNER TO PREVENT STANDING WATER ON HORIZONTAL SURFACES. SEAL ALL SEAMS WITH MASTIC DESIGNED FOR USE ON METAL DUCT, GLASS FIBER DUCT BOARD, AND FLEXIBLE DUCT. MASTIC SHALL BE UL 181 LISTED FOR THE APPLICATION USED.
16. INTERIOR CONCEALED DUCTWORK: ALL DUCT WORK ASSOCIATED WITH CONSTANT VOLUME AIR HANDLING EQUIPMENT SHALL BE CONSTRUCTED TO 2" W.G. AND SEALED TO SMACNA CLASS B. SEAL ALL SEAMS WITH MASTIC SEALANT UL 181 LISTED FOR THE APPLICATION USED. SEALANT SHALL BE DESIGNED FOR USE ON METAL DUCT AND FLEXIBLE DUCT.
17. INTERIOR EXPOSED DUCTWORK APPLICATION: RECTANGULAR AND ROUND SUPPLY AND RETURN DUCTWORK LOCATED IN EXPOSED INTERIOR AREAS SHALL BE INTERNALLY LINED WITH DUCT LINER AND EXTERNALLY PAINTED. REFER TO ARCHITECT FOR COLOR SELECTION.
18. INSTALL DX PIPING AS SPECIFIED, INCLUDING FILTER/DRYER, SIGHT GLASS, ISOLATION/CHARGING VALVES AND ALL APPURTENANCES PER MANUFACTURER'S RECOMMENDATIONS. INSTALLATION SHALL BE ACCOMPLISHED IN A NEAT AND ORDERLY FASHION, AS APPROVED BY THE ENGINEER. COORDINATE FOR ROUTING OF DX PIPING, UP INSIDE OF WALLS, ETC. AS REQUIRED, TERMINATING AT AIR HANDLING UNITS. PROVIDE BRACING/ISOLATION, AS REQUIRED TO PREVENT VIBRATION OF DX PIPING INSIDE WALLS. ETC. SIZE, ROUTE AND INSULATE DX PIPING PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATION REQUIREMENTS.
19. SEAL ALL DUCT PENETRATIONS THROUGH FIRE RATED BUILDING ELEMENTS WITH AN APPROVED FIRE PROOFING MATERIAL.
20. EXPAND OR REDUCE DUCTS AT EQUIPMENT CONNECTIONS BASED ON THE EQUIPMENT PURCHASED, WITH TRANSITIONS NOT TO EXCEED 30 DEGREES. SIZES SHOWN ON SCHEDULES, ETC. ARE FOR GUIDANCE ONLY. ASPECT RATIO SHALL BE NO GREATER THAN 4:1, PER SMACNA'S GUIDELINES.
21. ALL DUCTS WITH A DIMENSION GREATER THAN 12" PASSING THRU A NON-RATED WALL SHALL HAVE THE OPENING FRAMED IN WITH METAL STUDS. COORDINATE OPENING SIZE AND LOCATION WITH OTHER TRADES.
22. ALL EQUIPMENT LISTED TO UL508A OR UL 1995 SHALL HAVE A SHORT CIRCUIT CURRENT RATING (SCCR) OF THE ASSEMBLY MEETING OR EXCEEDING THE RATING OF THE PANEL FROM WHICH IT IS POWERED. SCCR RATINGS MAY BE REDUCED BASED ON ACTUAL CALCULATIONS BASED ON ACTUAL CONSTRUCTION AND IN ACCORDANCE WITH NEC. RATING SHALL BE STAMPED ON EQUIPMENT AT THE FACTORY. REFER TO ELECTRICAL FOR ADDITIONAL INSTRUCTIONS.

SYMBOLS

SYMBOL	DESCRIPTION
	ACOUSTICAL DUCT LINING (FIGURES SHOWN ARE INSIDE DUCT DIMENSIONS)
	SUPPLY AIR DUCT UP (POSITIVE PRESSURE)
	RETURN, EXHAUST OR OUTSIDE AIR INTAKE DUCT UP (NEGATIVE PRESSURE)
	SUPPLY AIR DUCT DOWN (POSITIVE PRESSURE)
	RETURN, EXHAUST OR OUTSIDE AIR INTAKE DUCT DOWN (NEGATIVE PRESSURE)
	ROUND DUCT UP
	ROUND DUCT DOWN
	RECTANGULAR DUCT SQUARE ELBOW WITH TURNING VANES
	RECTANGULAR DUCT RADIUS ELBOW
	ROUND DUCT RADIUS ELBOW
	TRANSITION CONCENTRIC UNLESS TOP LEVEL(TOP LVL) OR BOTTOM LEVEL(BOT LVL) IS NOTED
	TRANSITION, RECTANGULAR TO ROUND CONCENTRIC UNLESS TOP LEVEL (TOP LVL) OR BOTTOM LEVEL (BOT LVL) IS NOTED
	SQUARE CEILING DIFFUSER (SUPPLY)
	SQUARE CEILING GRILLE (RETURN OR EXHAUST)
	T = THERMOSTAT/TEMPERATURE SENSOR
	H = HUMIDISTAT/HUMIDITY SENSOR
	DUCT SPLITTER WITH DAMPER
	MOTORIZED DAMPER
	MANUAL VOLUME DAMPER
	FIRE DAMPER
	FIRE SMOKE DAMPER

BASIS OF MECHANICAL DESIGN


PRIMARY MECHANICAL CODES:

MECHANICAL: 2018 INTERNATIONAL MECHANICAL CODE (WITH CITY AMENDMENTS).
ENERGY: 2018 INTERNATIONAL ENERGY CODE (WITH CITY AMENDMENTS).

PROJECT DESIGN VALUES:

OUTDOOR DESIGN TEMPERATURE (SUMMER):	99°F (DRY BULB), 77°F (WET BULB)
AMBIENT TEMPERATURE AT CONDENSING UNITS:	105°F (DRY BULB, SUMMER)
OUTDOOR DESIGN TEMPERATURE (WINTER):	22°F (DRY BULB)
INDOOR DESIGN TEMPERATURE (SUMMER):	75°F (DRY BULB), 50% RH
INDOOR DESIGN TEMPERATURE (WINTER):	72°F (DRY BULB)
OUTSIDE AIR REQUIREMENTS:	PER IMC TABLE 403.3

DRAWING/DETAIL REFERENCE



MISCELLANEOUS

- ① DRAWING NOTE REFERENCE (I.E., NOTES BY SYMBOL)
- ⦿ CONNECTION INTO EXISTING

ABBREVIATIONS

AD	ACCESS DOOR	KW	KILOWATT
A/C	AIR CONDITIONING UNIT	L	LENGTH
A/E	ARCHITECT/ENGINEER	LAT	LEAVING AIR TEMPERATURE
AF	ABOVE FINISHED FLOOR	LPC	LOW PRESSURE CONDENSATE
AFF	ANYWHERE HAVING JURISDICTION	LPS	LOW PRESSURE STEAM
AFS	AIR FLOW SWITCH	LB	POUNDS
AHU	AIR HANDLING UNIT	LRA	LOCKED ROTOR AMPS
APPROX	APPROXIMATE	LWT	LEAVING WATER TEMPERATURE
BAS	BUILDING AUTOMATION SYSTEM	MAX	MAXIMUM
BHP	BRAKE HORSE POWER	MBH	1000 BRITISH THERMAL UNITS / HOUR
BTU	BTU'S THERMAL UNIT PER HOUR	MCA	MINIMUM CIRCUIT CAPACITY
C/A	COMBUSTION AIR	MCA	MANUFACTURER
CC	COOLING COIL	MIN	MINIMUM
CFH	CUBIC FEET PER HOUR	N/A	NOT APPLICABLE
CFM	CUBIC FEET PER MINUTE	N, O, N/C	NORMALLY OPEN, NORMALLY CLOSED
CLG	CONDENSING UNIT	OUTSIDE AIR	OUTSIDE AIR / FRESH AIR
CU	CONDENSING UNIT	OBD	OPPOSED BLADE DAMPER
D	EQUIPMENT DRAIN	O/C	ON CENTER
DEG	DEGREES	PEF	PURGE EXHAUST FAN
DN	DRY BULB	PH	PHASE
DB	DOWN	PROVIDE	FURNISH AND INSTALL
DX	DIRECT EXPANSION	PRV	PRESSURE REDUCING VALVE
(E)	EXISTING	PSI	POUNDS PER SQUARE INCH
EAT	ENTERING AIR TEMPERATURE	R/A	RETURN AIR
E/A	EXHAUST AIR	RE:	REFERENCE, REFER TO
EDH	ELECTRIC DUCT HEATER	RH	RELATIVE HUMIDITY
EF	EXHAUST FAN	RL	REFRIGERANT LIQUID
EQUIP	EQUIPMENT	RLA	RUNNING LOAD AMPS
ESP	EXTERNAL STATIC PRESSURE	ROOM	ROOM
EWT	ENTERING WATER TEMPERATURE	RPM	REVOLUTIONS PER MINUTE
'F	DEGREES FAHRENHEIT	RS	REFRIGERANT SUCTION
FCU	FAN COIL UNIT	S/A	SUPPLY AIR
FD	FIRE DAMPER	SD	SMOKE DETECTOR
FL	FULL LOAD AMPS	SF	SQUARE FOOT, SUPPLY FAN
FLR	FLOOR	SPECS	SPECIFICATIONS
FPVAV	FAN POWERED VAV	T, TSTAT	THERMOSTAT, ROOM SENSOR
FSD	FIRE SMOKE DAMPER	T/A	TRANSFER AIR
FT	FOOT, FEET	THRU	THROUGH
FT, WG	FEET WATER GAUGE	TSTAT	TOTAL STATIC PRESSURE
GA	U.S. GAUGE	TSTAT	THERMOSTAT OR ROOM SENSOR
GP/M	GALLONS PER MINUTE	TYP	TYPICAL
H	HEIGHT	UL	UNDERWRITERS' LABORATORIES, INC.
HP	HORSEPOWER	UH	UNIT HEATER
HPC	HIGH PRESSURE CONDENSATE	V	VOLTS
HPS	HIGH PRESSURE STEAM	VAV	VARIABLE AIR VOLUME
HWR	HEATING WATER RETURN	VEL	VELOCITY
HWS	HEATING WATER SUPPLY	VFD	VARIABLE FREQUENCY DRIVE
HZ	HERTZ	W/	WITH
IN.	INCH, INCHES	W/B	WET BULB
IN.WG	INCHES WATER GAUGE	W/O	WITHOUT
IN.WG	INCHES WATER GAUGE		

DEMOLITION WORK NOTES

GENERAL

1. EXISTING WORK SHOWN ON PLANS IS FROM AVAILABLE AS-DESIGNED DOCUMENTS AND LIMITED FIELD OBSERVATIONS. ACTUAL CONDITIONS MAY VARY; FIELD VERIFY EXISTING WORK AND MAKE MINOR ADJUSTMENTS NECESSARY TO COMPLETE WORK. IF EXISTING CONDITIONS PROHIBIT WORK, NOTIFY THE ARCHITECT FOR DIRECTION, AS REQUIRED.
2. WHERE EXISTING EQUIPMENT OR DUCTWORK IS LOCATED SUCH THAT IT IS ALONG THE TOP OF NEW WALLS TO DECK, IT SHALL BE RELOCATED. COORDINATE SUCH WORK WITH OTHER TRADES. RELOCATED EQUIPMENT SHALL BE TO A LOCATION THAT ALLOWS ACCESS FOR PERIODIC SERVICING AND REPAIR.
3. COORDINATE WITH ALL TRADES FOR REQUIRED CEILING REMOVAL IN EXISTING BUILDING. NOTIFY THE ARCHITECT AND OWNER PRIOR TO COMMENCING REMOVAL. REMOVE ONLY THAT PORTION OF THE CEILING NECESSARY TO ACCESS AND COMPLETE THE WORK. UPON COMPLETION OF THE ABOVE CEILING WORK, CEILING IS TO BE REINSTALLED. REPLACE ANY DAMAGED CEILING TILES WITH NEW TILES TO MATCH EXISTING.
4. DEMOLITION SHALL EXTEND TO POINTS OF CONNECTION WITH LIVE SERVICES (PANELBOARDS, PIPING MAINS, ETC). DEMOLITION SHALL NOT PERMIT ABANDONMENT OF ANY PORTION OF ANY SYSTEM UNLESS SPECIFICALLY NOTED AS "ABANDON IN PLACE" OR "TO REMAIN".
5. DEMOLITION SHALL INCLUDE EQUIPMENT, PIPING, DUCTWORK, SUPPORTS, FITTINGS, ACCESSORIES, CONTROLS, WIRING, CONDUIT, ETC, IN THEIR ENTIRETY UNLESS OTHERWISE NOTED.
6. VERIFY THE CONDITION OF ALL EXISTING EQUIPMENT WITHIN THE PROJECT SCOPE, EXACT SIZES OF EXISTING DUCT AND PIPING, ETC BEFORE COMMENCING DEMOLITION WORK. REPORT ANY DISCREPANCIES BETWEEN PLANS AND ACTUAL FIELD CONDITIONS TO ARCHITECT PRIOR TO THE COMMENCEMENT OF DEMOLITION WORK.
7. PATCH OPENINGS IN WALLS TO MAINTAIN THE INTEGRITY OF THE WALL WHERE AIR DEVICES HAVE BEEN REMOVED. REFER TO ARCHITECTURAL DRAWINGS/SPECIFICATIONS FOR ADDITIONAL INSTRUCTIONS.
8. THE LOCATION OF EXISTING UNDERGROUND UTILITIES IS SHOWN IN AN APPROXIMATE WAY ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR SHALL PAY FOR AND REPAIR ALL DAMAGES CAUSED BY FAILURE TO LOCATE AND PRESERVE UNDERGROUND UTILITIES.

EQUIPMENT

1. THE OWNER HAS THE FIRST RIGHT-OF-REFUSAL FOR ALL DEMOLISHED EQUIPMENT. THE CONTRACTOR IS RESPONSIBLE FOR REMOVAL AND PROPER DISPOSAL OF ANY EQUIPMENT REFUSED BY THE OWNER.
2. ALL REMOVED EQUIPMENT SHALL BE MAINTAINED IN GOOD CONDITION. REMOVED EQUIPMENT NOT INDICATED FOR RE-USE SHALL REMAIN THE PROPERTY OF THE OWNER. REMOVE THE EQUIPMENT AND DELIVER IT TO THE OWNER. SHOULD THE OWNER DECLINE THE POSSESSION OF THE REMOVED EQUIPMENT, IT SHALL BECOME THE PROPERTY OF THE CONTRACTOR FOR REMOVAL FROM SITE.
3. WHEN ALL CONSTRUCTION IS COMPLETE INSTALL NEW, CLEAN PRE-/POST-FILTERS IN AIR UNITS SERVING THE RENOVATED AREAS. VERIFY CONDITION OF UNIT FILTER GAUGES AND REPAIR OR REPLACE IF FOUND TO BE DAMAGED OR NON-FUNCTIONAL.

DUCTWORK

1. CAP AND SEAL AIR TIGHT ALL POINTS AT WHICH DUCTWORK IS REMOVED FROM DUCTWORK THAT WILL REMAIN. RE-INSULATE REMAINING DUCTWORK TO MAINTAIN VAPOR BARRIER.
2. TAKE AIR FLOW READINGS ON EACH FAN INLET, OUTSIDE AIR INTAKE, AND SUPPLY AIR FAN DISCHARGE, PRIOR TO DEMOLITION WORK. RECORD AND SUBMIT TO ARCHITECT/ENGINEER.
3. TAKE AIR READINGS OF ALL GRILLES, REGISTERS, AND DIFFUSERS IN PROJECT AREAS PRIOR TO DEMOLITION. RECORD AND SUBMIT TO ARCHITECT/ENGINEER.
4. VERIFY CLEARANCE REQUIREMENTS AND INDICATE ROUTING OF NEW DUCTWORK BEFORE FABRICATION BEGINS AS RISES AND DROPS MAY BE NECESSARY DUE TO EXISTING FIELD CONDITIONS.

CONTROLS

1. DEMOLITION AND/OR RELOCATION OF CONTROLS FOR EQUIPMENT SHALL INCLUDE, BUT NOT BE LIMITED TO:
SPACE AND DUCT THERMOSTATS
SPACE AND DUCT TEMPERATURE/HUMIDITY SENSORS;
SMOKE DETECTORS, FIRE-STATS, FREEZE-STATS, AND OTHER SAFETY OR LIMITING DEVICES;
RTU AND EXISTING CONTROL SYSTEMS CONTROL PANELS
2. VERIFY CONDITION OF ALL EXISTING LIFE SAFETY DEVICES (FIRE DAMPERS, DUCT DETECTORS, ETC) THAT ARE TO REMAIN AND ARE WITHIN LIMITS OF CONSTRUCTION. REPAIR OR REPLACE IF FOUND TO BE DAMAGED OR NON-FUNCTIONAL.

ARCHITECTURE

SCOTT MARTSOLF - ARCHITECT

815 Daggett Avenue
Fort Worth, Texas 76104

Phone: (817) 820-0005

ST. JUDE
CATHOLIC
CHURCH

PARISH HALL REMODEL & CONNECTOR BUILDING

500 E DALLAS ST.
MANSFIELD, TX 76063

BID SET

Drawing Title:


HVAC LEGENDS & NOTES

Project No.

2307	12/20/2023
------	------------

Sheet No.

MO.1



MEP Consultant
Rene' A. Culross
Rene' A. Culross, P.E., PLLC
1820 Hunting Green Drive
Fort Worth, TX 76134
817-798-6642
raculross@gmail.com
F-12230

2347.1219.6510